

**ADDENDUM NO. 2
REQUEST FOR PROPOSAL
#20-21-002
“Buck Mountain Communications Tower”**

1. **Change in Response Due Date:** The Response due date has been *changed from August 5th* to September 8th, 2020 at 2:00 pm MT. The original Sequence of Events” dates in the original RFP, page 5; II; A” have been changed accordingly.

A. SEQUENCE OF EVENTS

The Procurement Manager will make every effort to adhere to the following schedule:

Action	Responsibility	Date
Submission of Proposal	Potential Offeror (PO)	9/8/20 by 2:00 pm
Proposal Evaluation	Evaluation Committee	9/8/2020 2:30 pm
Approval of BOCC/ Contract award*	Approval of BOCC/	9/15/2020
Notification of Finalists	PM	9/16/2020
Contract Negotiations	Winner/County	9/25/2020 TBD
Protest Deadline	Offerors	October 1st, 2020
Start Performance	Winner	October 2nd, 2020

*Contract award is subject to approval of the Board of County Commissioners.

4. Construction Plans:

- a. The request for a “concrete” structure has been changed to a “fiberglass aggregate” exterior being acceptable due to the location of the site.
- b. The Shelter must have a “Ice Shield Canopy” installed.
- c. No gravel at the base of the site, keep terrain natural.

5. **Survey:** The County will provide a survey.

6. **Antennas clarifications:** Brackets will be at 110 ft with 3 antennas up and 3 antennas down. Antennas and hardware will be supplied by the County.

7. **The Generator housing** does not have to be housed in its own structure. As long as it is enclosed, as is the example photo.



Toni Foligno, Chief Purchasing Officer

Date:

Please acknowledge receipt of Addendum by email to tfoligno@lincolncountynm.gov